SERVICE SPEED SATISFACTION

WINANDY GREENHOUSE COMPANY, INC.

Greenhouse Manufacturers, Builders and Heating Engineers

New

"SUN-MATE"

ReNew

Phone (765) 935-2111

RICHMOND, INDIANA 47374 2211 PEACOCK ROAD SINCE 1919

Fax (765) 935-2110



October 19, 2021

Chester Community Greenhouse and Gardens

Attn: Cheryl Joy Lipton

PO Box 1271

Chester, VT 05143

RE: Double Glazing System attached to 1936 Lord & Burnham Master Iron Frame Greenhouse

Dear Cheryl,

We have reviewed the plans and photographs sent showing the 1936 Lord & Burnham Master Iron Frame greenhouse. We have examined the photographs carefully and find no sign of any significant deterioration in the heavy steel framework. Further, we can extend to you that the Lord & Burnham Master Iron Frame greenhouse was over engineered for its time and that we have successfully double glazed many of the same type of framework. The fact that your bay spacing is only 8'-4" is another plus in that they also had a 12'-6" bay spacing using almost the same steel members. That means your greenhouse was significantly over engineered for the time.

We can safety project that if this greenhouse is bolted together with proper bolts equivalent to those issued in 1936 and erected in the same manner as the greenhouse stood when it was new, it will support double glazing of the roof and vertical walls to give you the insulation of double glazing verses single glazing.

We hope this gives you the information you require. Please let us know if you need anything else.

Sincerely yours,

Michael J. Dohert

[&]quot;An amount equal to any tax or other governmental charge upon the production, sale, occupation of selling, shipment or use of material which is now or may be hereafter imposed by Federal, State or Municipal authorities upon either the purchaser or the Winandy Greenhouse Company, Inc., which the Winandy Greenhouse Company, Inc. is obliged to pay or collect, shall be added to the price and shall be paid by the Purchaser."